

Plumas County
Planning & Building Services
555 Main Street
Quincy, CA 95971
Office: (530) 283-7011
Fax: (530) 283-6134

Plumas County

e-mail

To: Cindy

From: Carolyn Vickers

Sherie Grate

Company:

Title: Permit Technician

Phone:

Date: 11-21-11

Address: Cindy@cin-d.com

● **Comments:**

Permit 02-1437

Hi Cindy,

these are the correction notices. Many corrections have been made. However because some corrections refer back to other notices, I sent them all to you. Please call if you have any questions.

Carolyn

PLUMAS COUNTY BUILDING DEPARTMENT

Correction Notice

Quincy Office 283-6062

Quincy Inspection Request Line 283-6001

Chester Office 258-2108

Name: Cook Permit #: 02-1437

Inspection: Final Re Date: 7-28-03 Inspector: Jeff Griggs

The following code violation(s) have been noted and will require correction:

- 1) Complet #s 1+2 From Date 6-6-03
- 2) Complet all landings and Decks from for all Exits from the Building as per 2001 C.B.C.
- 3) Provide a Hand rail at the Back Stair from the Deck
- 4) Provide power to the Building
- 5) Provide ~~OK~~ for the exterior gas lines
- 6) Complet all the Underfloor Vents
- 7) Provide that openings in the foundation are Not Below grade

Remainig Corrections are the Owners responsibility

- Contact Building Department A.S.A.P.
- Re-inspection of the above correction(s) will be required before any further work is done.
- Re-inspection required; however, work that will not conceal areas affected by the correction(s) noted above can proceed.

PLUMAS COUNTY BUILDING DEPARTMENT

Correction Notice

Quincy Office 283-6062

Quincy Inspection Request Line 283-6001

Chester Office 258-2108

Name: Cook

Permit #: 02-1437

Inspection: Final

Date: 6-6-03

Inspector: Jeff Griggs

The following code violation(s) have been noted and will require correction:

- 1) Remove all ~~the~~ Trees within 5' of the Foundation as per the Correction Dated 10-9-02. No Final Will Be Given unless this is done!!!
- 2) Remove the 6 AWG NM Cable that is being used to power the
- 3) Fix the ~~receptical~~ receptical outlets the Breakfast Nook and each side of the Double Doors
- 4) Fix the lights that don't work
- 5) Provide a deck, landings, stairs steps ramps, guardrails and handrails as needed
- 6) Provide the Underfloor Ventilation at 1 sq ft Per 150 sq ft Of Underfloor area
- 7) Provide 4" clearance from the earth for all Underfloor Ducts
- 8) Provide 8th Doors for the Underfloor access

- Contact Building Department A.S.A.P.
- Re-inspection of the above correction(s) will be required before any further work is done.
- Re-inspection required; however, work that will not conceal areas affected by the correction(s) noted above can proceed.

PLUMAS COUNTY BUILDING DEPARTMENT

Correction Notice

Quincy Office 283-6062

Quincy Inspection Request Line 283-6001

Chester Office 258-2108

Name: COOK, DAN YANILL

Permit #: 02-1437

Inspection: ROOF NATI

Date: 3-13-03

Inspector: [Signature]

The following code violation(s) have been noted and will require correction:

- 1.) ATTACHED PORCH @ SOUTH END OF MORTLE HOME IS ON PLANS BUT NO STATE APPROVAL EXISTS FOR ATTACHMENT -
- 2.) ICF DAM IS REQUIRED @ ENDS TO 30" IN FROM TOP PLATE
- 3.) FURTHER WORK @ PORCH ATTACHMENT IS NOT RECOMMENDED UNTIL ENGINEER OF DESIGN AND PLUMAS COUNTY PLANNING DEPT APPROVES THE ATTACHMENT PROCEDURES USED.

[Signature]
3-13-03

- Contact Building Department A.S.A.P.
- Re-inspection of the above correction(s) will be required before any further work is done.
- Re-inspection required; however, work that will not conceal areas affected by the correction(s) noted above can proceed.

PLUMAS COUNTY BUILDING DEPARTMENT

Correction Notice

Quincy Office 283-6062

Quincy Inspection Request Line 283-6001

Chester Office 258-2108

Name: Cook

Permit #: 02-1437

Inspection: Final

Date: 6-03

Inspector: Jett Griggs

The following code violation(s) have been noted and will require correction:

9) Repair ~~the~~ plastic under the Manufactured Home that is ~~repaired~~ Damaged

- Contact Building Department A.S.A.P.
- Re-inspection of the above correction(s) will be required before any further work is done.
- Re-inspection required; however, work that will not conceal areas affected by the correction(s) noted above can proceed.

PLUMAS COUNTY BUILDING DEPARTMENT

Correction Notice

Quincy Office 283-6062

Quincy Inspection Request Line 283-6001

Chester Office 258-2108

Name: Cook

Permit #: 02-1437

Inspection: Manometer

Date: 12-18-02

Inspector: Jeff Griggs

The following code violation(s) have been noted and will require correction:

1) Provide a test for the Interior gas lines

2) Complet the Correction from 10-9-02 ~~and~~ as per Plamas County Code Sec. 8-9.06 See Code on second page

Note: No Inspections Will be taken until # 2 is completed

- Contact Building Department A.S.A.P.
- Re-inspection of the above correction(s) will be required before any further work is done.
- Re-inspection required; however, work that will not conceal areas affected by the correction(s) noted above can proceed.

PLUMAS COUNTY BUILDING DEPARTMENT

Correction Notice

Quincy Office 283-6062

Quincy Inspection Request Line 283-6001

Chester Office 258-2108

Name: Cook Permit #: 02-1437

Inspection: Foundation Date: 6-9-02 Inspector: Jeff Griggs

The following code violation(s) have been noted and will require correction:

1) Remove all trees within 5 feet of the foundation

- Contact Building Department A.S.A.P.
- Re-inspection of the above correction(s) will be required before any further work is done.
- Re-inspection required; however, work that will not conceal areas affected by the correction(s) noted above can proceed.