

[Print](#) | [Close Window](#)

Subject: Reaming Correction Items

From: "Cunningham, John" <JohnCunningham@countyofplumas.com>

Date: Tue, Nov 22, 2011 11:52 am

To: "cindy@cin-d.com" <cindy@cin-d.com>

Cindy,

Re: Building Permit #02-1437
Cook, Dan & Nell
2369 Ashley Ave
Prattville, CA
APN: 001-283-004

Confirming our phone conversation this morning, the following reaming correction notice items from the final re-inspection of 7-28-03 are required to be corrected to pass the final inspection (items 4 and 5 I neglected to discuss with you) :

- 1. Remove the #6 NM cable (electrical wire) that is being used to provide electrical power to the home.
- ok 2. In an approved manner, complete all landings and decks at all exterior doors.
- ok 3. Provide approved handrail at the back stairway.
- ok 4. Complete installation of foundation vents.
- ok 5. Confirm that all openings in the foundation wall (foundation vents, underfloor access, etc.) are not below finish grade.

The requirement to remove all trees within 5' of the foundation (while arguably a good idea) is waived, as County Code will be changed in the near future to omit this requirement.

Should you have any questions, please feel free to contact me.

John Cunningham
Building Official

(530) 283-7011 department line
(530) 283-6206 direct line
(530) 283-6134 fax

FINAL IS COMPLETE AS SOON AS POWER IS SWITCHED OVER TO NEW 200 AMP PANEL - NO FURTHER INSPECTIONS REQUIRED EXCEPT TO VERIFY WORK IS INSTALLED @ NEW PANEL

John M. Lyne
11-29-2011

Copyright © 2003-2011. All rights reserved.